Tagore education Society
Rotary public school
Ranebennur.

RANEBENNUR 24x7 WATER SUPPLY

WATER SAMPLE COLLECTION FOR WATER QUALITY ANALYSIS

As part of the O&M Period "SCHEDULE - 1 : Obligations of the Contractor" two water samples have been collected as detailed below:

1. Date of sample collection 31/03/2026

2. Water sampling and testing details:

Q.NR: 28949

Parameter	Sample Ref. No.	Sampling Location	Result	Sample collected by Signature & Name
Residual Chlorine (RC) in ppm		Zone no : 02 Location: Near OHT	0.4 ppm	Madhukumar.S Madhu.S
		Zone no.: 02 Location: Rotaryschool Railway station Road	0.2 ppm	Madhukumar S Madhu.S
Bacteriological &		Zone no.: Location:	Refer Lab report	
Pressure Measured at Consumer HSC (in m)				

3. Witness by :

Organisation	Represented by	Designation	Signature
Veolia India Pvt Ltd	Madhukumar.S	Engineer	Madhu.S
KUIDFC, Ranebennur	Shekhar Hadimani	AEE	
Ranebennur CMC	Raju G. Bhovi	Sr. Health Inspector	
Technical Auditor	Chuda Chandra	R E	
Customer Shivakumar.S	Lat : 14.623598	Lan : 75.636062	

Mob:-8553724346

Note:

1. RC to be tested 2 times/ week and at 2 locations; one water sample to be collected at the exit of a clear water pump house or outlet of any service reservoir and the second water sample to be collected within the customer premises either near PMP or any farthest location from the service reservoir.
2. Bacteriological tests 1time/ month and at one location; water sample to be collected at any location within the water supply system.

Principal
Rotary Public School
Ranebennur
Dise Code: 29114100892

Manager
Rotary Public School
Station Road, Ranebennur

SECRETARY
Tagore Education Society
Ranebennur

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated: 31.3.2026

It is certified that an inspection team headed by Raju G. Bhovi Sr. Health Inspector (Name of Officers with designation) from C.M.C. Ranebennur PHED inspected the Tagore Education Society Rotary Public School Ranebennur (Name & Address of the school) on 31.3.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. ..... dated 31.3.2026 of ..... (PHED Lab) certified that the Rotary Public School Ranebennur Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 30.9.2026

Signature with Seal: 31/3/26
Name : Raju G. Bhovi
Designation : Sr. Health Inspector
Name & Address of the Office / Department : .....
ಪೌರಾಯುಕ್ತರ ರಾಣೇಬೆನ್ನೂರ
ನಗರಸಭೆ, ರಾಣೇಬೆನ್ನೂರು

To
Tagore Education Society
Rotary Public School Ranebennur.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
Rotary Public School
Ranebennur Dt. Haveri
Dise Code: 29114100992

Manager
Rotary Public School
Station Road, Ranebennur

SECRETARY
Tagore Education Society
Ranebennur